

# Pool/Spa Maintenance Log

Facility Name: \_\_\_\_\_ Month: \_\_\_\_\_ Year: \_\_\_\_\_

Day	Pool		Spa			Other		Maintenance Notes
	Free-Chlorine Residual (1ppm-10ppm) With CYA (2ppm-10ppm)	pH Level (7.2-7.8)	Free-Chlorine Residual (3ppm-10ppm) With CYA (3ppm-10ppm)	pH Level (7.2-7.8)	Spa Temp (Max 104 Degrees)	Free-Chlorine Residual (3ppm-10ppm) With CYA (3ppm-10ppm)	pH Level (7.2-7.8)	
1								
2								
3								
4								
5								
6								
7								
8								
9								
10								
11								
12								
13								
14								
15								
16								
17								
18								
19								
20								
21								
22								
23								
24								
25								
26								
27								
28								
29								
30								
31								

California Health & Safety Code 65523(b): Cyanuric acid (CYA) shall be measured a minimum of once per month. Shasta County recommends testing more frequently when there are known issues with high CYA, in the summer months, and in the Spa.

Date: \_\_\_\_\_ Pool: \_\_\_\_\_ Spa: \_\_\_\_\_ Other: \_\_\_\_\_ Max Level 100ppm