STI SP001 Annual Inspection Checklist (6th Edition)

General Inspection Information:

Inspection Date:	Prior Inspection Date:
Inspector Name (print):	
Inspector's Signature	
Tank(s) inspected or ID #s	

Inspection Guidance:

- This checklist is intended as a model. Locally developed checklists are acceptable as long as they are substantially equivalent (as applicable).
- For equipment not included in this Standard, follow the manufacturer recommended inspection/testing schedules and procedures.
- The periodic AST Inspection is intended for monitoring the external AST condition and its containment structure. This visual inspection does not require a Certified Inspector. It shall be performed by an owner's inspector per paragraph 4.1.2 of the standard.
- Remove promptly standing water or liquid discovered in the primary tank, secondary containment area, interstice, or spill container. Before discharge to the environment, inspect the liquid for regulated products or other contaminants and disposed of it properly.
- In order to comply with EPA SPCC (Spill Prevention, Control and Countermeasure) rules, a facility should regularly test liquid level sensing devices to ensure proper operation (40 CFR 112.8(c)(8)(v)).
- Non-conforming items important to tank or containment integrity require evaluation by an engineer experienced in AST design, a Certified Inspector, or a tank manufacturer who will determine the corrective action. Note the non-conformance and corresponding corrective action in the comment section.
- Retain the completed checklists for at least 36 months.
- Complete this checklist on an annual basis, supplemental to the owner monthly-performed inspection checklists.
- Note: If a change has occurred to the tank system or containment that may affect the SPCC plan, the condition should be evaluated against the current plan requirement by a Professional Engineer knowledgeable in SPCC development and implementation.

current plan requirement by a Professional Engineer knowledgeable in SPCC development and implementation.				
ITEM	STATUS	COMMENTS/DATE CORRECTED		
Tank Foundation/Supports				
Free of tank settlement or foundation washout?	□ Yes □ No			
Concrete pad or ring wall free of cracking and spalling?	□Yes □No □NA			
Tank supports in satisfactory condition?	□ Yes □ No □ NA			
Is water able to drain away from tank if tank is resting on a foundation or on the ground?	□Yes □No □NA			
Is the grounding strap between the tank and foundation/supports in good condition?	□ Yes □ No □ NA			
Tank Shell, Heads, and Roof				
Free of visible signs of coating failure?	□ Yes □ No			
Free of noticeable distortions, buckling, denting, or bulging?	□ Yes □ No			
Free of standing water on roof?	□ Yes □ No □ NA			
Are all labels and tags intact and legible?	□ Yes □ No			
Tank Manways, Piping, and Equipment				
Flanged connection bolts tight and fully engaged with no sign of wear or corrosion?	□ Yes □ No □ NA			
Tank Equipment				
Normal and emergency vents free of obstructions?	□ Yes □ No			
Normal vent on tanks storing gasoline equipped with pressure/vacuum vent?	□ Yes □ No □ NA			

Are flame arrestors free of corrosion and are air passages free of blockage?	□ Yes □ No □ NA			
Is the emergency vent in good working condition and functional, as				
required by manufacturer? Consult manufacturer's requirements. Verify	□ Yes □ No □ NA			
that components are moving freely (including long-bolt manways).	2 165 2 116 2 11			
Is interstitial leak detection equipment in good condition? Are windows				
on sight gauges clear? Are wire connections intact? If equipment has a	□ Yes □ No □ NA			
test function, does it activate to confirm operation?"				
Are all valves free of leaks, corrosion and other damage? Follow				
manufacturers' instructions for regular maintenance of these items.				
Check the following and verify (as applicable):				
□ Anti-siphon valve	□ Yes □ No □ NA			
□ Check valve	□ Yes □ No □ NA			
□ Gate valve	□ Yes □ No □ NA			
□ Pressure regulator valve	□ Yes □ No □ NA			
□ Expansion relief valve	□ Yes □ No □ NA			
□ Solenoid valve	□ Yes □ No □ NA			
□ Fire valve	□ Yes □ No □ NA			
□ Shear valve	□ Yes □ No □ NA			
Are strainers and filters clean and in good condition?	□ Yes □ No □ NA			
Insulated	Tanks			
Free of missing insulation?	Tuliks			
Insulation free of visible signs of damage?	□ Yes □ No □ NA			
Insulation adequately protected from water intrusion?	110 110			
Insulation free of noticeable areas of moisture?	□ Yes □ No □ NA			
Insulation free of mold?	□ Yes □ No □ NA			
Free of visible signs of coating failure?	□ Yes □ No □ NA			
Tank / Piping Rele	ease Detection			
Is inventory control being performed and documented if required?	□ Yes □ No □ NA			
Is release detection being performed and documented if required?	□ Yes □ No □ NA			
Other Equ	inment			
Other Equ	притенс			
Are electrical wiring and boxes in good condition?	□ Yes □ No □ NA			
Has the cathodic protection system on the tank been tested as required by the designing engineer?	□ Yes □ No □ NA			
by the designing engineer:				
Additional Comments:				